



Florida Department of Environmental Protection

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

February 19, 2016

In the Matter of an
Application for Permit by:

PERMITTEE:

Mr. Robert Moreyra, Managing Member
CRP II-Tarpon Springs LLC
2501 South MacDill Avenue
Tampa, Florida 33629
RMoreyra@ForgeCapitalPartners.com

PERMIT NUMBER:

CS52-0117033-101-DWC/CM

COUNTY:

Pinellas

PROJECT NAME:

Meres Crossing Phase III

WWTF NAME:

City of Tarpon Springs

FACILITY ID:

FL0030406

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number CS52-0117033-101-DWC/CM to construct a domestic wastewater collection/transmission system, issued pursuant to 403.087(1), Florida Statutes.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Section 120.60(3), Florida Statutes, however, also allows that any person who has asked the Department in writing for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for extension of time within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party)

PROJECT NAME: Meres Crossing Phase III
PERMIT NUMBER: CS52-0117033-101-DWC/CM

will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected, each agency's file or identification number, if known, and the county in which the project is located;
- (b) The name, address, any e-mail address, any facsimile number, and telephone number of the petitioner, if the petitioner is not represented by an attorney or a qualified representative; the name, address, and telephone number of the petitioner's representative, if any; which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final on the date filed with the Clerk of the Department unless a petition (or request for extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this permit will not be effective until further order of the Department.

Any party to the permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the Clerk of the Department.

PROJECT NAME: Meres Crossing Phase III
PERMIT NUMBER: CS52-0117033-101-DWC/CM

Executed in Hillsborough County, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION




for Pamala Vazquez
Program Administrator
Permitting & Waste Cleanup Program
Southwest District

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated deputy clerk, receipt of which is hereby acknowledged.

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed before the close of business on this date to the listed persons.


[Clerk]

February 19, 2016
[Date]

Copies furnished to:
Mr. JD Alsabbagh, P.E., Sycamore Engineering, Inc., jalsabbagh@sycamoreeng.com
Frank L. Fulghum III, City of Tarpon Springs, ffulghum@ctsfl.us



Florida Department of Environmental Protection

Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

Jonathan P. Steverson
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER COLLECTION/TRANSMISSION INDIVIDUAL PERMIT

PERMITTEE:	PERMIT NUMBER:	CS52-0117033-101-DWC/CM
Mr. Robert Moreyra, Managing Member CRP II-Tarpon Springs LLC 2501 South MacDill Avenue Tampa, Florida 33629 RMoreyra@ForgeCapitalPartners.com	ISSUE DATE:	February 19, 2016
	EXPIRATION DATE:	February 18, 2021
	COUNTY:	Pinellas
	PROJECT NAME:	Meres Crossing Phase III
	WWTF NAME:	City of Tarpon Springs
	FACILITY ID:	FL0030406
	PROCESSOR:	Raji Ravindran

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4 and 62-604, Florida Administrative Code (F.A.C.).

The above named permittee is hereby authorized to construct the facilities shown on the application and other documents on file with the Department and made a part hereof and specifically described as follows:

DESCRIPTION OF PROJECT:

Construction of a domestic wastewater collection/transmission system to serve 236 apartment units. This project consists of eight-inch diameter gravity pipes and seven manholes.

LOCATION OF PROJECT:

The domestic wastewater collection/transmission system is located in Section 13, Township 27, and Range 15 of Pinellas County, Florida.

IN ACCORDANCE WITH: The limitations, requirements and other conditions set forth in pages 1 through 3 of this permit.

PROJECT NAME: Meres Crossing Phase III
PERMIT NUMBER: CS52-0117033-101-DWC/CM

PERMIT CONDITIONS:

1. This permit is subject to the general conditions of Rule 62-4.160, F.A.C., as applicable. This rule is available at the Department's Internet site at:
<http://www.dep.state.fl.us/water/rulesprog.htm#ww> [62-4.160]
2. Upon completion of construction of the collection/transmission system project, and before placing the facilities into operation for any purpose other than testing for leaks or testing equipment operation, the permittee shall submit to the Department's Southwest District Office Form 62-604.300(8)(b), Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation. This form is available at the Department's Internet site at:
<http://www.dep.state.fl.us/water/wastewater/forms.htm> [62-604.700(2)]
3. The new or modified collection/transmission facilities shall not be placed into service until the Department clears the project for use. [62-604.700(3)]
4. Permit revisions shall only be made in accordance with Rule 62-4.050(4)(s), F.A.C. Request for revisions shall be made to the Department in writing and shall include the appropriate fee. Revisions not covered under Rule 62-4.050(4)(s), F.A.C., shall require a new permit. [62-604.600(8)]
5. Abnormal events shall be reported to the Department's Southwest District Office in accordance with Rule 62-604.550, F.A.C. For unauthorized spills of wastewater in excess of 1000 gallons per incident, or where information indicates that public health or the environment may be endangered, oral reports shall be provided to the STATE WATCH OFFICE TOLL FREE NUMBER, (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee or other designee becomes aware of the circumstances. Unauthorized releases or spills less than 1000 gallons per incident are to be reported orally to the Department's Southwest District Office within 24 hours from the time the permittee, or other designee becomes aware of the circumstances. [62-604.550]
6. This permit is for CONSTRUCTION ONLY of the collection/transmission system project. This permit does not authorize the connection of this collection/transmission system project to the designated wastewater treatment plant. This permit shall not be construed to infer that the clearance necessary for connection shall be granted. Any such clearance shall be granted only when reasonable assurance is given that adequate treatment and disposal is available in accordance with Department rules, regulations, and permits. Partial clearance may be granted, if required. [62-604.130(1) and 62-604.600(7)]

PROJECT NAME: Meres Crossing Phase III
PERMIT NUMBER: CS52-0117033-101-DWC/CM










Executed in Hillsborough County, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

A handwritten signature in blue ink, appearing to be 'P. Vazquez', is written over a horizontal line.

for Pamala Vazquez
Program Administrator
Permitting & Waste Cleanup Program
Southwest District

LOCATION OF PUBLIC WATER SYSTEM MAINS IN ACCORDANCE WITH F.A.C. RULE 62-555.314

Other Pipe	Horizontal Separation	Crossings (1)	Joint Spacing @ Crossings (Full Joint Centered)
Storm Sewer, Stormwater Force Main, Reclaimed Water (2)	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">3 ft. minimum</p>	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">12 inches is the minimum, except for storm sewer, then 6 inches is the minimum and 12 inches is preferred</p>	<p style="text-align: center;">Alternate 3 ft. minimum</p>  <p style="text-align: center;">Water Main</p>
Vacuum Sanitary Sewer	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">10 ft. preferred 3 ft. minimum</p>	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">12 inches preferred 6 inches minimum</p>	<p style="text-align: center;">Alternate 3 ft. minimum</p>  <p style="text-align: center;">Water Main</p>
Gravity or Pressure Sanitary Sewer, Sanitary Sewer Force Main, Reclaimed Water (4)	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">10 ft. preferred 6 ft. minimum (3)</p>	 <p style="text-align: center;">Water Main</p> <p style="text-align: center;">12 inches is the minimum, except for gravity sewer, then 6 inches is the minimum and 12 inches is preferred</p>	<p style="text-align: center;">Alternate 6 ft. minimum</p>  <p style="text-align: center;">Water Main</p>
On-Site Sewage Treatment & Disposal System	10 ft. minimum	---	---

- (1) Water main should cross above other pipe. When water main must be below other pipe, the minimum separation is 12 inches.
 (2) Reclaimed water regulated under Part III of Chapter 62-610, F.A.C.
 (3) 3 ft. for gravity sanitary sewer where the bottom of the water main is laid at least 6 inches above the top of the gravity sanitary sewer.
 (4) Reclaimed water not regulated under Part III of Chapter 62-610, F.A.C.

Disclaimer – This document is provided for your convenience only. Please refer to F.A.C. Rule 62-555.314 for additional construction requirements.